
SNOW COLLEGE SOUTH CAMPUS WASHBURN BUILDING ART STUDIO AND NAIL SALON HVAC UPGRADES

DFCM PROJECT #04225710 RICHFIELD, UTAH





State of Utah—Department of Administrative Services

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

4110 State Office Building / Salt Lake City, Utah 84114 / 538-3018

MECHANICAL ENGINEER

WHW ENGINEERING, INC.

1354 EAST 3300 SOUTH

SUITE 200

SALT LAKE CITY, UTAH 84106

PHONE: (801) 466-4021 FAX: (801) 466-8536



ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
1354 East 3300 South Suite 200
SALT LAKE CITY, UTAH 84106

(801)466-4021, FAX 466-8536

EMAIL: excellence@whw-engineering.com

1704 West Sunset Boulvard #4

St.George, Utah 84770

PHONE: (435) 628-3670 FAX: (435) 628-3680

ELECTRICAL ENGINEER

DRAWING INDEX:

M-000 TITLE SHEET

M-001 GENERAL MECHANICAL NOTES AND LEGEND

PE-101 PLUMBING FLOOR PLAN

MD-101 MECHANICAL DEMOLITION PLAN

ME-101 MECHANICAL REMODEL PLAN

ME-501 MECHANICAL DETAILS

ME-502 MECHANICAL DETAILS

ME-601 MECHANICAL SCHEDULES

EG-101 ELECTRICAL SYMBOLS, NOTES, AND SCHEDULES

EL-101 ELECTRICAL FLOOR PLAN



SYMBOL	ABR.	DESCRIPTION	SYMBOL	ABR.	DESCRIPTION
AIR SIDE	[/\.	Describing the state of the sta	WET SIDE	/ (D) (I)	Desertii Hert
₩		EXISTING AIR DUCT TO BE REMOVED			PUMP
		EXISTING AIR DUCT TO REMAIN			UNION
<u></u>		NEW AIR DUCT			MANUAL ACTUATOR (BALL, BUTTERFL
		RECT. TO RECT. AIR DUCT TAKE-OFF			NEEDLE, ETC. VALVES)
		RECT. TO RND. AIR DUCT TAKE-OFF			MANUAL ACTUATOR (GATE, GLOBE,
		RND. TO RND. AIR DUCT TAKE-OFF			S&D, OS&Y, ETC. VALVES)
		RECT. TAKE-OFF AT END OF MAIN	\Box		PNEUMATIC DIAPHRAGM ACTUATOR
→		FLEXIBLE AIR DUCT	M		ELECTRIC MOTOR ACTUATOR
		LINED DUCT			THREADED OR SWEAT VALVE CONNECTION
		VANED ELBOW			FLANGED VALVE CONNECTION
		RADIUS ELBOW	— [—		BUTTERFLY VALVE
		CONCENTRIC DUCT TRANSITION			GATE VALVE
		ECCENTRIC DUCT TRANSITION			GLOBE VALVE - STRAIGHT PATTERN
		FLEXIBLE DUCT CONNECTION	M		MOTORIZED 2-WAY CONTROL VALVE
VD		VOLUME DAMPER	M		MOTORIZED 3-WAY CONTROL VALVE
		SUPPLY AIR DIFFUSER	——————————————————————————————————————		CHECK VALVE
		RETURN AIR, FRESH AIR, AND TRANSFER AIR		CBV	CIRCUIT BALANCING VALVE
		CEILING MOUNTED EXHAUST FAN OR	<u> </u>	BV	BALL VALVE
		EXHAUST GRILLE RETURN OR OUTSIDE AIR DUCT UP	\	PRV	PRESSURE RELIEF VALVE
		SUPPLY DUCT UP	— 3D —	TDV	TRIPLE DUTY VALVE
		EXHAUST AIR INTAKE UP		TDV	TRIPLE DUTY VALVE - ANGLE
		RETURN OR OUTSIDE AIR DUCT DOWN			<u>22 23 11 77,272</u> 71,1822
		SUPPLY DUCT DOWN		TDV	TRIPLE DUTY VALVE - STRAIGHT
		EXHAUST DUCT DOWN			THE EDOTT WILL STRUCT
		ROUND DUCT UP			AUTOMATIC AIR VENT
		ROUND DUCT DOWN			MANUAL AIR VENT
		FLEXIBLE DUCT CONNECTION			STRAINER
	AP	ACCESS PANEL			STRAINER W/ PLUGGED BLOW OFF
		EXISTING EQUIPMENT TO BE REMOVED	\B		PRESSURE GAUGE AND GAUGE COC
		EXISTING EQUIPMENT TO REMAIN			-WATER
		NEW EQUIPMENT	:13		THERMOMETER AND THERMOWELL
A	Α	AUTOMATIC DAMPER			THERWOWETER AND THERWOWELE
BD	BD	BACKDRAFT DAMPER			WATER TEMPERATURE SENSOR
F>			S		AND THERMOWELL
	FD FS	FIRE DAMPER FIRE & SMOKE DAMPER	1.1	TW	THERMONATH
(NID)				1 00	THERMOWELL DDESS & TEMP, TAP
	T'STAT				PRESS. & TEMP. TAP
2		WALL MOUNTED TEMP. SENSOR	0		ELBOW DOWN
SA		SUPPLY AIR	C		ELBOW DOWN
RA		RETURN AIR			TEE DOWN
EA .		EXHAUST AIR			TEE DOWN
CA		COMBUSTION AIR			EXISTING PIPING TO BE REMOVED
MA		MIXED AIR			EXISTING PIPING TO REMAIN
FA		FRESH AIR			NEW PIPING
RF		RELIEF AIR			PIPE CAP OR PLUG
GENERAL	TERMI				CONCENTRIC REDUCER
A		SECTION LETTER DESIGNATION			ECCENTRIC REDUCER
M-5		- SECTION DRAWN ON THIS SHEET			FLEXIBLE CONNECTION
2		DETAIL NUMBER DESIGNATION	—CD—		CONDENSATE DRAIN
M-5		- DETAIL DRAWN ON THIS SHEET	—GF—		GLYCOL FEED LINE
AH		- MECHANICAL EQUIPMENT DESIGNATION	— ми —		MAKE-UP WATER LINE
1		- EQUIPMENT ITEM DESIGNATION		CW	CULINARY COLD WATER
D-1		REGISTER, GRILLE OR DIFFUSER DESIGNATION WITH BALANCING		HW	CULINARY HOT WATER
	I	CFM LISTED BELOW	-HWS-		HEATING WATER SUPPLY
CFM		<u></u>		<u> </u>	
CFM R-1		GRILLE, OR LOUVER DESIGNATION WHERE BALANCING NOT REQUIRED	-HWR-		HEATING WATER RETURN

GENE	RAL TE	RMINOLOGY CONT.	WET SIDE	CON	T.
Â		REVISION DESIGNATOR AND NUMBER	-LPR -		LOW PRESSURE STEAM RETURN
1		KEY NOTE DESIGNATOR AND NUMBER	HGS—		HEATING GLYCOL SUPPLY
•	POC	POINT OF CONNECTION	HGR-		HEATING GLYCOL RETURN
$\overline{\bullet}$	POR	POINT OF REMOVAL	s		REFRIGERANT SUCTION LINE
GC		GENERAL CONTRACTOR	— L—		LIQUID SUCTION LINE
МС		MECHANICAL CONTRACTOR	—нс —		HOT GAS BYPASS LINE
СС		CONTROL CONTRACTOR			
EC		ELECTRICAL CONTRACTOR			
FPC		FIRE PROTECTION CONTRACTOR			
NIC		NOT IN CONTRACT			
NTS		NOT TO SCALE			
С		COMMON			
NC		NORMALLY CLOSED			
NO		NORMALLY OPEN			

MECHANICAL GENERAL NOTES:

MECHANICAL INFORMATION IS NOT LIMITED TO THE MECHANICAL DRAWINGS. CONTRACTOR SHALL BE RESPONSIBLE FOR INFORMATION ON ALL OTHER CONSTRUCTION DOCUMENTS INCLUDING DRAWINGS BY OTHER DISCIPLINES AND SPECIFICATIONS.

A - EACH DRAWING SHEET AND THE SPECIFICATIONS HAVE BEEN PREPARED TO SUPPLEMENT EACH OTHER AND THEY SHALL BE INTERPRETED AS AN INTEGRAL UNIT WITH ITEMS SHOWN AND NOTED ON ONE AND NOT THE OTHER BEING FURNISHED AND INSTALLED AS THOUGH SHOWN AND CALLED OUT IN ALL PLACES. ITEMS IN SPECIFICATIONS OR DRAWINGS LISTED WHICH ARE DIFFERING IN EFFICIENCY OR QUALITY SHALL BE HELD TO THE GREATEST OF: EFFICIENCY, QUALITY OR GOVERNING CODE.

B - THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR THE INSTALLATION OF THE SYSTEMS ACCORDING TO THE TRUE INTENT AND MEANING OF THE CONTRACT DOCUMENTS.

C - THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT WITH PROPER SERVICE ACCESS AND CLEARANCES ACCORDING TO MANUFACTURERS RECOMMENDATIONS. THE CONTRACTOR SHALL REVIEW SUPPLIERS BID PACKAGES FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS, SCHEDULES, AND DESIGN INTENT (ALL EQUIPMENT AND METHODS). THE CONTRACTOR SHALL REMOVE AND REINSTALL CORRECTLY AT HIS OWN EXPENSE ANY EQUIPMENT NOT IN COMPLIANCE.

D - THE CONTRACTOR SHALL CONSULT MANUFACTURERS INSTALLATION INSTRUCTIONS FOR SIZES, METHODS, ACCESSORIES AND CLEARANCES IN SPACE AVAILABLE PRIOR TO BIDDING PROJECT.

E - ANYTHING NOT CLEAR OR IN CONFLICT WILL BE EXPLAINED BY MAKING APPLICATION TO THE ENGINEER IN WRITING.

ANY AND ALL ALTERATIONS TO THE SYSTEM SHOWN SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR. ENGINEER SHALL BE NOTIFIED IN WRITING PRIOR TO CHANGES.

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND LOCATIONS.

THE WORKING DRAWINGS ARE DIAGRAMMATIC. THEY DO NOT SHOW EVERY OFFSET, BEND, OR ELBOW NECESSARY FOR THE COMPLETE INSTALLATION IN THE SPACE PROVIDED. ALL LOCATIONS FOR MECHANICAL EQUIPMENT SHALL BE FIELD VERIFIED AND COORDINATED WITH ALL DRAWINGS. THE CONTRACTOR SHALL PROVIDE PROVISIONS FOR BLOCKOUTS OR CORE DRILLS THROUGH STRUCTURE.

THE INSTRUCTION TO "PROVIDE" ALSO INCLUDES INSTALLATION.

MECHANICAL CONTRACTOR SHALL PROVIDE AND INSTALL SMOKE AND FIRE DAMPERS AS REQUIRED BY LOCAL CODES AND AUTHORITIES.

SHEET METAL DUCT SIZES SHOWN ON DRAWINGS ARE FREE AREA DIMENSIONS.

PROVIDE AND INSTALL BALANCING DAMPERS IN ALL SUPPLY AIR AND EXHAUST AIR BRANCH DUCTS, BALANCE TO CFM SHOWN ON PLAN.

PROVIDE TURNING VANES IN ALL ELBOWS OF RECTANGULAR DUCT.

THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY IN HANDLING AND DISPOSING OF REFRIGERANTS, OILS, ETC. ALL SUCH MATERIALS SHALL BE HANDLED, DISPOSED, AND USED ON ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS.

THE MECHANICAL CONTRACTOR SHALL VERIFY MOTOR VOLTAGES WITH THE ELECTRICAL DRAWING BEFORE ORDERING MOTORIZED EQUIPMENT AND CONTROLS. MOTOR NAMEPLATE VOLTAGE SHALL BE NEMA STANDARD 200 VOLT FOR 208 VOLT, THREE PHASE SYSTEM AND SHALL BE NEMA STANDARD 230 VOLT FOR 240 VOLT, THREE PHASE, OR SINGLE PHASE SYSTEM.

C.F.M. LISTED IS ACTUAL AIR.

SUPPLIERS SHALL REVIEW ALL DRAWINGS AND THE SPECIFICATIONS PRIOR TO SUBMITTING PRICES TO THE CONTRACTOR. ALL QUESTIONS AND DISCREPANCIES SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO BIDDING.


CONTRACTOR SHALL THOROUGHLY REVIEW AND SIGN SUBMITTALS FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS PRIOR TO ENGINEERS REVIEW. SUPPLIERS SHALL HIGHLIGHT OR MARK ALL INFORMATION REQUIRED TO SHOW COMPLIANCE TO THE SPECIFICATIONS. ALL REQUESTED EXCEPTIONS TO THE SPECIFICATIONS, OR SCHEDULES SHALL BE CLEARLY NOTED AND EXPLAINED. SUBMITTAL REVIEW AND ACCEPTANCE IS FOR DESIGN CONCEPT ONLY, AND DOES NOT AT ANY TIME RELIEVE THE CONTRACTOR OF RESPONSIBILITY TO MEET SPECIFICATIONS, CAPACITIES, OR DESIGN INTENT.

ALL MECHANICAL SHALL BE INSTALLED AND CONFORM TO THE 2003 EDITION OF THE IMC AND IPC WITH UTAH ANNOTATIONS COLLEGE REQUIREMENTS.

FOR FINAL REVIEW NOT FOR CONSTRUCTION

State of Utah


Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. PROFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536 EMAIL: excellence@whw-engineering.com

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC. These documents are protected under the United States 1978

copyright act. It is an exclusive work of original authorship None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used r re-used for any purpose without the express prior writte permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

SNOW COLLEGE SOUTH RICHFIELD CAMPUS

DFCM# 04225710

RICHFIELD, UTAH

MARK	DATE		REV	ISION		
PROJECT	MANAGI WP	ER:				
DRAWN	BY: STAFI	7		03/09/0	ENCE	
CHECKE		•	<i>¶ ¶/≈/</i> y	VINWAR	D M.\⇔'	1


CHECKED BY: SLW 03/09/05 WHW JOB NO.:


04036 SHEET TITLE


GENERAL NOTES

AND LEGENDS

M001








SHEET NOTES

- PROVIDE ROOF MOUNTED EXHAUST FAN. CONNECT EXHAUST DUCTWORK TO NEW HOODS. SEE SCHEDULES AND DETAILS SHEET.
- $\langle 2 \rangle$ PROVIDE CAPTURE HOOD FOR AIR BRUSH TABLES. SEE SCHEDULES AND DETAILS SHEET.
- $\langle 3 \rangle$ PROVIDE CAPTURE HOOD FOR LACQUER TABLE. SEE SCHEDULES AND DETAILS.
- $\langle 4 \rangle$ PROVIDE ROOF MOUNTED INDIRECT FIRED MAKE-UP AIR UNIT WITH PACKAGED COOLING. PROVIDE WITH VIBRATION ISOLATION AND SEISMIC ROOF CURB, RETURN AIR BY-PASS, ETC. SEE SCHEDULES AND DETAILS SHEET. INSTALL TO SPAN AS MANY ROOF JOISTS AS POSSIBLE. PROVIDE ADDITIONAL STRUCTURAL BRACING
- (5) PROVIDE CEILING TRANSFER GRILLES. PROVIDE 32"x16" TRANSFER AIR OPENING IN BLOCK WALL ABOVE CEILING AND 32"x16" FIRE DAMPER.
- $|\langle 6
 angle$ PROVIDE NEW VAV BOX WITH HOT WATER COIL. RE-CONNECT TO EXISTING DUCT AND PIPING. SEE SCHEDULES AND DETAILS SHEET.
- $\langle 7
 angle$ PROVIDE NEW VENTILATION CAPTURE HOOD. SUPPORT FROM STRUCTURE PER MANUFACTURERS RECOMMENDATIONS. RE-LOCATE AND RE-CONFIGURE EXISTING AIR PIPING, AIR HOSES, ANY OTHER UTILITIES AS NECESSARY TO ACCOMMODATE NEW HOODS.
- 8 PROVIDE AUTOMATIC ELECTRO MECHANICAL DOOR CLOSERS FOR THE TWO DOORS SEPERATING THE ART STUDIO AND ART CLASSROOM. POWER AND FIRE ALARM INTERLOCK FOR NEW CLOSERS.
- (9) REPLACE EXISTING CEILING TILES IN ART STUDIO TO MATCH EXISTING. MODIFY GRID AS NECESSARY TO ACCOMMODATE NEW HOODS
- $\langle 10 \rangle$ SEE SHEET PE101 FOR FIRE SPRINKLER
- PROVIDE FIRE DAMPER WHERE RETURN DUCT
- \$\langle 12 \rangle PROVIDE HOT WATER PIPING TO NEW HEATING COIL & MAKE UP AIR UNIT MA-2. PIPE PER DETAIL A3 THIS SHEET. TIE INTO EXISTING HOT WATER SUPPLY & RETURN PIPING. FIELD VERIFY.
- (13) PROVIDE HEATING HOT WATER PIPING TO NEW VAV BOX. TIE INTO EXISTING PIPING. FIELD VERIFY. PIPE PER DETAIL C1/ME502.

State of Utah Department of Administrative Services

Division of Facilities



Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. ROFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536

COPYRIGHT NOTICE

ALL RIGHTS RESERVED ©

WHW ENGINEERING, INC. These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship. None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method. mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS


SNOW COLLEGE SOUTH RICHFIELD CAMPUS

DFCM# 04225710

RICHFIELD, UTAH

MARK	DATE	REVISION

KEY PLAN




PROJECT MANAGER: DRAWN BY: STAFF HECKED BY:


03/09/05

04036

MECHANICAL FLOOR PLAN

ME101






DETAIL SCALE: NONE **SQUARE-TO-ROUND** TAKE-OFF DETAIL SCALE: NONE


✓ INSULATION

DUCT


COLLAR



DUCT LINER DETAIL



ROUND DUCT SUPPORT DETAIL




DUCT STRAP HANGER DETAIL SCALE: NONE

SPACING.

CEILING

DIFFUSER

 $\overline{L=1/4}$ W (4" MINIMUM.)



BRANCH DUCT TAKE-OFF & DAMPER DETAIL SCALE: NONE

- 1												
	LOW PRESSURE ROUND DUCT CONSTRUCTION SCHEDULE											
	DUCT		IM 2" W.G. POSITIVE	MAXIMUN STATIC N								
	DIAMETER	SPIRAL	LONGITUDINAL	SPIRAL	LONGITUDINAL							
	IN INCHES	SEAM GAUGE	SEAM GAUGE	SEAM GAUGE	SEAM GAUGE							
	3 thru 8	28	28	28	24							
	9 thru 14	28	26	26	24							
	15 thru 26	26	24	24	22							
	27 thru 36 24 22 22 20											
	37 thru 50	22	20	20	18							


LOW PRESSURE ROUND **DUCT CONSTRUCTION DETAIL**

				TRA	NSVERSE F	REINFORCIN	G (1)					
		MINIMUM	AT JOINTS									
DIMENSION OF LONGEST SIDE, INCHES	SHEET METAL GAGE (ALL FOUR SIDES)	REINFORCING ANGLE SIZE AND MAXIMUM LONGITUDINAL SPACING BETWEEN TRANSVERSE JOINTS &/OR	MIN. H. IN.	S DRIVE SLIP PLAIN S SLIP	HEMMED S SLIP	ALTER'NT BAR SLIP	REIN- FORCED BAR SLIP					
		INTERMEDIATE REINFORCING		RECOM- MENDED GAGE	RECOM- MENDED GAGE	RECOM- MENDED GAGE	RECOM- MENDED GAGE					
UP THRU 12	26	NONE REQUIRED	1	26	26	24	24					
13 - 18	24	NONE REQUIRED	1	24	24	24	24					
19 - 30	24	1"X1"X1/8" @ 60 IN	1	-	24	24	24					
31 - 36	22	1"X1"X1/8" @ 60 IN	1	_	_	22	22					

1. TRANSVERSE REINFORCING SIZE IS DETERMINED BY DIMENSION OF SIDE TO WHICH ANGLE IS APPLIED.




FOR FINAL REVIEW NOT FOR CONSTRUCTION State of Utah Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. ROFESSIONAL MECHANICAL ENGINEERI 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536 EMAIL: excellence@whw-engineering.com

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC.

These documents are protected under the United States 197 copyright act. It is an exclusive work of original authorship None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

SNOW COLLEGE SOUTH RICHFIELD CAMPUS

DFCM# 04225710

RICHFIELD, UTAH


MARK	DATE	REVISION

DRAWN BY: CHECKED BY: 03/09/05

WHW JOB NO.:

MECHANICAL DETAILS

ME501



		DIFFU	JSER S	CHE	DULE					
			FACE	NECK	CEILINIC			AIR DIST./SIDE		
SYMBOL	TYPE	MAX CFM 2	SIZE	SIZE	CEILING TYPE	BLOW	PATTERN	A (%)	B (%)	
D-1 CFM	CEILING	200	9x9	8"	24x24 LAY-IN	4-WAY	⊗ BA ⊗⊗	25	25	
D-2 CFM	CEILING	200	9x9	8"	24x24 LAY-IN	3-WAY	⊗ BA	31	38	
D-3 CFM	CEILING	270	12x12	10"	24x24 LAY-IN	3-WAY	⊗ BA	31	38	
D-4 CFM	CEILING	485	15x15	12"	24x24 LAY-IN	4-WAY	BA ■ ■	?	?	
D-5 CFM	CEILING	485	15x15	12"	24x24 LAY-IN	3-WAY	⊗ BA	31	38	
D-6 CFM	CEILING	975	22x22	22x22	24x24 LAY-IN	4-WAY	⊗ BA ⊗⊗	25	25	
D-7 CFM	CEILING	975	22x22	22x22	24x24 LAY-IN	3-WAY	⊗ BA ⊗ M	31	38	
D-8 CFM	CEILING	975	22x22	22x22	24x24 LAY-IN	2-WAY	& BA □ ▶	25	25	

			I	NDIR	ECT (GAS I	FIRE	D MA	۱KE-	·UP	All	R UN	IIT S	SCHE	DULE
SYMBOL	INPUT	CFM	T.S.P.	HEAT	HEATING (2)		COOLING		MOTOR			I NACA	MOCD	MANUFACTURER & MODEL NUMBER 2	
STWIDOL	MBH	CFIVI	IN. W.C.	EADB	LAT	EADB	EAWB	LADB	VOLT	Hz	Ø	HP	MCA	MOCP	MANUFACTURER & MODEL NUMBER
MA 1	230	2050	0.6	0	80	95	63	60	460	60	3	0.75	22	30	AAON RM-006 (1)3)5)8
MA 2	780	8500	0.75	0	68	95	63	57.5	460	60	3	5.0	54	60	AAON RM-025 (1)4)5)8
	1) PROVIDE WITH OPTIONAL PETLIPN AIR BY BASS CONTROL OF SPACE STATIC PRESSURE SEE 15010														

- 1) PROVIDE WITH OPTIONAL RETURN AIR BY-PASS. CONTROL OFF SPACE STATIC PRESSURE. SEE 15910.
- ② CONDITIONS AT ALTITUDE OF 5270'.
- 3 BALANCE MINIMUM OUTSIDE AIR TO 400 CFM WHEN IN RETURN BY-PASS.
- 4 BALANCE MINIMUM OUTSIDE AIR TO 2000 CFM WHEN IN RETURN BY-PASS.
- (5) PROVIDE WITH POWER EXHAUST CONTROLLED FROM SPACE STATIC. COORDINATE WITH SECTION 15910.
- 6 PROVIDE WITH ROOF CURB.
- (7) PROVIDE WITH UNIT MOUNTED DISCONNECT.
- 8 PROVIDE WITH SUPPLY AND RETURN DUCT SMOKE DETECTORS. COORDINATE WITH DIV. 16 TO WIRE.
- (9) PROVIDE WITH HOT GAS BYPASS. COORDINATE WITH ATC TO CONTROL TO MAINTAIN DISCHARGE AIR TEMPERATURE.
- ① PROVIDE LAY-IN CEILING AND BORDER / MODULE AS REQUIRED. SEE ARCHITECTURAL CEILING PLANS.
- ② MAXIMUM NC 25 AT CFM LISTED.

	VAV BOX SCHEDULE															
SYMBOL	SERVES	INLET DIA. (IN)	INLET VEL. (FPM)	MAX CFM	COOL MIN CFM	ING MAX APD (IN)	COIL EAT	COIL LAT	MAX CFM	EATING COIL MBTUH	(40 FLOW GPM)° DELTA	(FT) PD	ROWS	NC LEVEL	MANUFACTURER & MODEL #
VAV 101	COMPUTER ROOM	12"	?	1200	400	0.16	55	80	850	24.1	2	180	0.56	1	21	PRICE SDV-12

	HOT WATER COIL SCHEDULE											
SYMBOL	SYMBOL SIZE C.F.M. MBH EAT LAT AIR PRESS. PRESS. DROP FT. HEAD G.P.M EWT LWT REMARKS											
HWC 1	45"x60"	8500	158	55	75	0.20	5.0	8.0	180	140	2	

- 1) 500 FPM MAX. FACE VELOCITY
- ② COIL SHALL BE PROVIDED BY THE SAME SUPPLIER AS THE ROOFTOP MAKE-UP AIR UNIT. SEE SPECIFICATIONS.

	HOOD INFORMATION												
				Е	XHAUST F	PLENUM			HOOD				
HOOD	MODEL	LxW	TOTAL			RISER(S)			CONSTRUCTION				
NO.		EXH. CFM	WIDTH	LENG.	DIA.	CFM	S.P.	CONOMICONO					
H	CAPTIVE AIRE	14.5'x4.5'	2200	16	16		1650	-0.50	00400				
1	5424 VH1-G	14.5 84.5	3300	16	16		1650	-0.50	304SS				
H	CAPTIVE AIRE	14.5'x4.5'	3300	16	16		1650	-0.50	20400				
2	5424 VH1-G	14.5 84.5	3300	16	16		1650	-0.50	304SS				
$\frac{H}{3}$	CAPTIVE AIRE 6624 VHI-G	8'x5.5'	2200	19	19		2200	-0.60	304SS				

- ① PROVIDE WITH ALUMINUM MESH FILTER.
- 2 PROVIDE WITH INCADENSCENT LIGHT.

		1	EXHAU	JST FAI	N SCHE	DULE		
SYMBOL	LOCATION	CONTROL TYPE	MIN. ① C.F.M.	STATIC PRESSURE IN. W.G.	POWER HP	VOLTS	MANUFACTURER & MODEL NO.	COMMENTS
EF 1	ART STUDIO HOOD #1	6	3300	1.25	1.5	120/1/60	PENN DOMEX DX18B	5 230
EF 2	ART STUDIO HOOD #2	6	3300	1.25	1.5	120/1/60	PENN DOMEX DX18B	<u> </u>
EF 3	ART STUDIO HOOD #3	6	2200	1.25	1.0	120/1/60	PENN DOMEX DX18B	5 230
EF 4	NAIL SALON	6	720	0.5	1/6	120/1/60	PENN DOMEX DX16V	5 123
EF 5	NAIL SALON	6	620	0.5	1/6	120/1/60	PENN DOMEX DX16V	5 0 23(
EF 6	NAIL SALON	6	920	0.5	1/3	120/1/60	PENN DOMEX DX16S	5 ①②③(

- ① SET BALANCE DAMPERS TO CFM LISTED ON PLANS.
- ② PROVIDE WITH UNIT MOUNTED DISCONNECT.
- ③ PROVIDE BACKDRAFT DAMPER IN OUTLET OF EXHAUST FAN
- 4 PROVIDE WITH BIRD SCREEN
- ⑤ OR EQUAL BY OTHER MANUFACTURERS IN SPECIFICATIONS.
- 6 PROVIDE WITH WALL SWITCH

	REGISTER, LOUVER & GRILLE SCHEDULE												
SYMBOL		TYPE	SERVICE	MAX CFM ①	NOMINAL SIZE	THROAT SIZE	CEILING TYPE	COMMENTS 2					
	EG-1 CFM	CEILING	EA	360	12x12	10"Ø	LAY-IN 4	PRICE 535 ③					
	EG-2 CFM	CEILING	EA	460	14x14	12"Ø	LAY-IN 4	PRICE 535 ③					
	R-1 CEILING		RA	540	16x16	16x16	LAY-IN 4	PRICE 535 ③					
	R-2	CEILING	RA	1265	22x22	22x22	LAY-IN 4	PRICE 535 ③					
	TG-1 CFM	CEILING	TA	1265	22x22	NA	LAY-IN 4	PRICE 535 ③					

REGISTER. LOUVER AND DIFFUSER SCHEDULE NOTE S:

- ① MAXIMUM NC = 25 @ MAXIMUM CFM NOTED.
- 2 SEE SPECIFICATIONS FOR APPROVED MANUFACTURERS.
- ③ FINISH SHALL BE OFF-WHITE BAKED ENAMEL.
- 4 PROVIDE 24x24 LAY-IN MODULE.

FOR FINAL REVIEW NOT FOR CONSTRUCTION

State of Utah Department of Administrative Services



Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536 EMAIL: excellence@whw-engineering.com

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC. These documents are protected under the United States 1978

copyright act. It is an exclusive work of original authorship. None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

SNOW COLLEGE SOUTH RICHFIELD CAMPUS

DFCM# 04225710

RICHFIELD, UTAH

DATE	REVISION
	DATE

PROJECT MANAGER: WP DRAWN BY: STAFF CHECKED BY: SLW 03/09/05 WHW JOB NO.: 04036

MECHANICAL

ME601

SCHEDULES

	EQUIPMENT SCHEDULE														
								WI	RES	00	PD	RE	F. NO	TES	
UNIT #	FUNCTION	LOAD	VOLT	PHASE	FULL LOAD AMPS	CONDUIT	NO. SETS	NO.	SIZE	TYPE	AMPS	STARTER	DISCONNECT	отнек	REMARKS
EF-1	EXHAUST FAN	1 HP	120	1	16.00	3/4"	1	2	12	СВ	30	4A			
EF-2	EXHAUST FAN	1 HP	120	1	16.00	3/4"	1	2	12	СВ	30	4A			
EF-3	EXHAUST FAN	1 HP	120	1	16.00	3/4"	1	2	12	СВ	30	4A			
EF-4	EXHAUST FAN	1/6 HP	120	1	4.40	3/4"	1	2	12	CB	15	4A			
EF-5	EXHAUST FAN	1/6 HP	120	1	4.40	3/4"	1	2	12	CB	15	4A			
EF-6	EXHAUST FAN	1/3 HP	120	1	7.20	3/4"	1	2	12	СВ	15	4A			
MA-1	MAKE-UP AIR	11.2 MCA	480	3	9.50	3/4"	1	3	12	СВ	20	8B			
MA-2	MAKE-UP AIR	51 MCA	480	3	43.10	3/4"	1	3	6	СВ	90	8B			

NOTES:


- 1. NON-FUSED DISCONNECT SWITCH
- 2. FUSED DISCONNECT SWITCH 3. BREAKER IN ENCLOSURE
- 4. MANUAL STARTER W/THERMAL OVERLOAD
- 5. MAGNETIC STARTER 6. MAGNETIC STARTER/NON-FUSED DISCONNECT COMBINATION
- 7. MAGNETIC STARTER/FUSED DISCONNECT COMBINATION
- 8. MAGNETIC STARTER/BREAKER COMBINATION
- 9. VARIABLE FREQUENCY DRIVE 10. REDUCED VOLTAGE STARTER
- 11. DIRECT CONNECTION
- 12. RECEPTACLE/SPECIAL PURPOSE OUTLET/ETC.
- 13. TWO-SPEED STARTER, COORDINATE W/MOTOR TYPE
- A. FURNISHED, INSTALLED, AND CONNECTED UNDER DIVISION 16 B. FURNISHED AND INSTALLED UNDER ANOTHER DIVISION REQUIRING CONNECTION UNDER DIVISION 16.

C. FURNISHED UNDER ANOTHER DIVISION BUT INSTALLED AND

CONNECTED UNDER DIVISION 16. D. FURNISHED, INSTALLED AND CONNECTED UNDER ANOTHER DIVISION. 4

- OVER CURRENT PROTECTIVE DEVICES
- CB = CIRCUIT BREAKER THERMAL MAGNETIC FN = FUSE - NON INDUCTIVE LOADFI = FUSE - INDUCTIVE LOAD

MO = MAGNETIC ONLY CIRCUIT BREAKER



TYPICAL RACEWAY SUPPORT METHODS

GENERAL NOTES

VERIFY ALL EQUIPMENT DIMENSIONS AND LOCATIONS BEFORE BEGINNING ROUGH IN. CONSULT ALL APPLICABLE CONTRACT DRAWINGS AND SHOP DRAWINGS TO INSURE NEC CODE CLEARANCES REQUIRED AROUND ALL ELECTRICAL EQUIPMENT.

SEE FIXTURE SCHEDULE FOR TYPE, MOUNTING AND WATTAGE.
HEIGHT MEASURED TO TOP LINE OF THE BOX FROM THE FINISH FLOOR.
REFER TO DRAWINGS FOR DIRECTIONAL ARROWS.

PROVIDE H.O.A. AND S.S. PUSHBUTTONS AS REQUIRED. DOUBLE ARROWS DENOTE A DOUBLE FACE UNIT.

STANDARD MOUNTING HEIGHT UNLESS OTHERWISE NOTED ON PLANS

ONE CIRCUIT, TWO WIRE HOME RUN TO PANEL

CONDUIT RUN CONCEALED IN WALL OR CEILING

CONDUIT RUN CONCEALED IN FLOOR OR GROUND

MANUAL STARTER THERMAL OVERLOAD SWITCH WITH PILOT LIGHT

MAGNETIC STARTER / DISCONNECT COMBINATION

3 CIRCUIT, 4 WIRE, COMMON NEUTRAL HOME RUN

2 CIRCUIT, 3 WIRE, COMMON NEUTRAL HOME RUN

10. SUBSCRIPT DENOTES NEMA CONFIGURATION.

DESCRIPTION

CONDUIT UP

CONDUIT DOWN

MOTOR OUTLET

PANEL BOARD

CONDUIT STUB LOCATION

NON-FUSED DISCONNECT SWITCH

FUSED DISCONNECT SWITCH

MAIN DISTRIBUTION PANEL

FIRE ALARM CONTROL MODULE

FIRE ALARM MONITOR MODULE

ARCHITECTURAL ROOM NUMBER

LIGHT FIXTURE (LETTER DESIGNATES TYPE)

DUCT SMOKE DETECTOR

FIRE ALARM RELAY

EQUIPMENT NUMBER

SYMBOL

*/*O/

 \bigcirc D

R

СМ

MM

842

SUBSCRIPT KEYS SWITCH TO FIXTURES CONTROLLED.

NEMA TYPE 'ND' NON-FUSED UNLESS NOTED 'F' (FUSED). USE 'HD' 480 V.
HEIGHT TO BE THE LOWER OF EITHER 80" A.F.F. OR 6" BELOW CEILING.

COORDINATE WITH MILLWORK SHOP DRAWINGS AND ELEVATIONS FOR HEIGHT.

HEIGHT MEASURED TO BOTTOM OF THE BOX FROM FINISH FLOOR.

- CONTRACTOR SHALL VERIFY ALL ELECTRICAL LOADS (VOLTAGE, PHASE, CONNECTION REQUIREMENTS, ETC.) OF EQUIPMENT FURNISHED UNDER DIVISION 15 WITH APPROVED MECHANICAL SHOP DRAWINGS BEFORE BEGINNING ROUGH IN.
- SEE SPECIFICATIONS FOR REQUIRED COORDINATION MEETINGS WITH MECHANICAL AND CEILING
- 4. SEE APPLICABLE SHOP DRAWINGS FOR ROUGH IN LOCATION OF ALL EQUIPMENT, WIRING DEVICES, ETC.
- THE ELECTRICAL CONTRACTOR SHALL NOTIFY AND COOPERATE WITH THE MECHANICAL CONTRACTOR SUCH THAT NO PIPING, DUCTS, OR EQUIPMENT FOREIGN TO THE OPERATION OF THE ELECTRICAL EQUIPMENT SHALL BE PERMITTED TO BE INSTALLED IN, ENTER OR PASS THRU ELECTRICAL ROOMS OR SPACES, OR ABOVE OR BELOW ELECTRICAL EQUIPMENT IN
- ELECTRICAL BOXES SHALL NOT BE LOCATED IN MASONRY COLUMNS IN BRICK WALLS OR IN GROUTED CELLS ADJACENT TO OPENINGS. COORDINATE LOCATION OF BOXES WITH MASONRY
- 7. ALL PENETRATIONS OF FIRE RATED FLOORS, WALLS, AND CEILINGS SHALL BE SEALED WITH APPROVED MATERIAL TO MAINTAIN FIRE RATING OF SURFACE PENETRATED.
- 8. CIRCUITS EXTENDING OVER 70' FOR 120 VOLT AND 165' FOR 277 VOLT 20 AMP CIRCUITS SHALL BE RUN WITH MINIMUM #10 CONDUCTORS.

DEMOLITION NOTES

- 1. COORDINATE ALL NEW ELECTRICAL EQUIPMENT REQUIREMENTS AND MAKE CONNECTION TO EXISTING SYSTEMS. THIS INCLUDES LIGHTING, POWER, SIGNAL, RACEWAY AND OTHER SYSTEMS INCLUDED UNDER DIVISION 16.
- 2. RELOCATE, REWIRE AND/OR RECONNECT EXISTING ELECTRICAL DEVICES AND/OR EQUIPMENT THAT FOR ANY REASON OBSTRUCTS CONSTRUCTION.
- 3. CONCEAL ALL RACEWAY AND WIRING IN EXISTING WALLS, CEILINGS, FLOORS, ETC. EXCEPT WHERE THE USE OF SURFACE METAL RACEWAYS (E.G. WIRE MOLD) IS INDICATED ON
- 4. LEAVE ALL EXISTING EQUIPMENT, IN PORTIONS OF THE BUILDING NOT BEING REMODELED, IN WORKING CONDITION. RESTORE ALL INTERRUPTED BRANCH CIRCUITS, FEEDERS, ETC. TO
- 5. EXISTING RACEWAYS MAY BE REUSED (IN PLACE) WHERE POSSIBLE, AND WHERE IN COMPLIANCE WITH THE SPECIFICATIONS AND THE INTENT OF THE CONTRACT DOCUMENTS. INSURE INTEGRITY OF EXISTING RACEWAY BEFORE REUSE.
- 6. REMOVE ALL RACEWAYS, CONDUCTORS, BOXES, DEVICES, EQUIPMENT, ETC. THAT ARE NOT TO
- 7. REMOVE EXISTING LIGHT FIXTURES WHICH ARE NOT TO BE REUSED, PLACE IN CARTON, LABEL APPROPRIATELY, AND RETURN TO OWNER, OR PROPERLY DISPOSE OF FIXTURES THAT THE OWNER CHOOSES NOT TO KEEP.
- 8. DO NOT PENETRATE STRUCTURAL ELEMENTS OF FLOORS, WALLS, CEILINGS, ROOFS, ETC.
- DISCONNECT AND RECONNECT ANY/ALL FIXTURES, DEVICES, EQUIPMENT, ETC. REQUIRED FOR PROPER COMPLETION OF THE WORK.

INDEX OF ELECTRICAL DRAWINGS

EG101 SYMBOLS, NOTES & SCHEDULES

WORKING CONDITION.

EL101 ELECTRICAL FLOOR PLAN

State of Utah Department of Administrative Services ELECTRICAL SYMBOL SCHEDULE

NOTES

CAP CONDUIT

+5'-0" 5.


+5'-0" 5.

+4'-0" 2.

MTD. IN DUCT

+5'-0"

Division of Facilities



Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267


Internet: http://www.dfcm.state.ut.us

CONSULTANTS





WHW



COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC.

These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.


PROJECT NAME & ADDRESS

SNOW COLLEGE SOUTH RICHFIELD CAMPUS

DFCM# 04225710

RICHFIELD, UTAH


MARK	DATE	REVISION
PROJECT	MANAGI	FR·



SYMBOLS, NOTES & SCHEDULES

EG101

DIAGRAM (HOO3)







DRAFTING SERVICE

INDEX

A-1	DEMOLITION	PLAN/	FLOOR	P




DEMOLITION PLAN



FLOOR PLAN

GENERAL NOTES



CONSTRUCTION DETAILS

A — 2

